



December 11, 2025

Lauren Doherty
Intertek PSI
17 British American Boulevard
Latham, NY 12110

RE: Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Dear Lauren Doherty:

Enclosed are the analytical results for sample(s) received by the laboratory on November 26, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads 'Lori Beyer'.

Lori A. Beyer
lori.beyer@pacelabs.com
516-370-6014
Project Manager

Enclosures

cc: Lauren Doherty, Intertek PSI



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: G7B		Lab ID: 70393989001		Collected: 11/25/25 16:48		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: G11A		Lab ID: 70393989002		Collected: 11/25/25 16:54		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: G11B		Lab ID: 70393989003		Collected: 11/25/25 16:54		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: G15A		Lab ID: 70393989004		Collected: 11/25/25 16:58		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:05	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: G15B		Lab ID: 70393989005		Collected: 11/25/25 16:58		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: G15C		Lab ID: 70393989006		Collected: 11/25/25 16:58		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.7	ug/L	1.0	1	12/08/25 07:29	12/08/25 17:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: F17		Lab ID: 70393989007		Collected: 11/25/25 17:02		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: B1B7		Lab ID: 70393989008		Collected: 11/25/25 17:10		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	47.1	ug/L	1.0	1	12/08/25 07:29	12/08/25 17:54	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: B1B9		Lab ID: 70393989009		Collected: 11/25/25 17:09		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.6	ug/L	1.0	1	12/08/25 07:29	12/08/25 18:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: B1B6		Lab ID: 70393989010		Collected: 11/25/25 17:12		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.5	ug/L	1.0	1	12/08/25 07:29	12/08/25 18:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN L		Lab ID: 70393989011		Collected: 11/25/25 16:30		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN M		Lab ID: 70393989012		Collected: 11/25/25 16:30		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN N		Lab ID: 70393989013		Collected: 11/25/25 16:32		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8									
Pace Analytical Services - Melville									
Lead	17.8	ug/L	1.0	1	12/08/25 07:29	12/08/25 18:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: F14		Lab ID: 70393989014		Collected: 11/25/25 16:37		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.8	ug/L	1.0	1		12/08/25 16:14	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: C1C		Lab ID: 70393989015		Collected: 11/25/25 16:40		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: C1D		Lab ID: 70393989016		Collected: 11/25/25 16:40		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:16	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: C2C		Lab ID: 70393989017		Collected: 11/25/25 16:43		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:17	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: C2D		Lab ID: 70393989018		Collected: 11/25/25 16:43		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: G3		Lab ID: 70393989019		Collected: 11/25/25 16:47		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8									
Pace Analytical Services - Melville									
Lead	2.0	ug/L	1.0	1	12/10/25 07:17	12/10/25 17:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: G7A		Lab ID: 70393989020		Collected: 11/25/25 16:48		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN B		Lab ID: 70393989021		Collected: 11/25/25 16:17		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		12/08/25 16:29	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: KITCHEN C		Lab ID: 70393989022		Collected: 11/25/25 16:17		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN D		Lab ID: 70393989023		Collected: 11/25/25 16:18		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:34	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: KITCHEN E		Lab ID: 70393989024		Collected: 11/25/25 16:18		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:35	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: KITCHEN F		Lab ID: 70393989025		Collected: 11/25/25 16:19		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN G		Lab ID: 70393989026		Collected: 11/25/25 16:23		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN H		Lab ID: 70393989027		Collected: 11/25/25 16:23		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:39	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: KITCHEN I		Lab ID: 70393989028		Collected: 11/25/25 16:25		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.0	ug/L	1.0	1		12/08/25 16:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN J		Lab ID: 70393989029		Collected: 11/25/25 16:25		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.3	ug/L	1.0	1		12/08/25 16:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN K		Lab ID: 70393989030		Collected: 11/25/25 16:26		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:45	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: 64		Lab ID: 70393989031		Collected: 11/25/25 15:54	Received: 11/26/25 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		12/08/25 16:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: 80		Lab ID: 70393989032		Collected: 11/25/25 15:57		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		12/08/25 16:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 82		Lab ID: 70393989033		Collected: 11/25/25 15:58		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		12/08/25 16:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: 84A		Lab ID: 70393989034		Collected: 11/25/25 15:59		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:50	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 84B		Lab ID: 70393989035		Collected: 11/25/25 16:05		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:52	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 84C		Lab ID: 70393989036		Collected: 11/25/25 16:05		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	2.2	ug/L	1.0	1		12/08/25 16:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 84D		Lab ID: 70393989037		Collected: 11/25/25 16:06		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:54	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: 84E		Lab ID: 70393989038		Collected: 11/25/25 16:06		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 16:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 84F		Lab ID: 70393989039		Collected: 11/25/25 16:10		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.6	ug/L	1.0	1		12/08/25 16:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: KITCHEN A		Lab ID: 70393989040		Collected: 11/25/25 16:12		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: F12C		Lab ID: 70393989041	Collected: 11/25/25 15:30	Received: 11/26/25 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/25 17:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: F13		Lab ID: 70393989042		Collected: 11/25/25 15:35		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:13	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 24A		Lab ID: 70393989043		Collected: 11/25/25 15:43		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		12/08/25 17:14	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 24B		Lab ID: 70393989044		Collected: 11/25/25 15:43		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		12/08/25 17:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 23A		Lab ID: 70393989045		Collected: 11/25/25 15:45		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:16	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 23B		Lab ID: 70393989046		Collected: 11/25/25 15:45		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: 58		Lab ID: 70393989047		Collected: 11/25/25 15:48		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 60		Lab ID: 70393989048		Collected: 11/25/25 15:48		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	19.8	ug/L	1.0	1		12/08/25 17:20	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: F12A		Lab ID: 70393989049		Collected: 11/25/25 15:50		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:21	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 62		Lab ID: 70393989050		Collected: 11/25/25 15:52		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.8	ug/L	1.0	1		12/08/25 17:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 66A		Lab ID: 70393989051		Collected: 11/25/25 15:15		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.1	ug/L	1.0	1		12/08/25 17:24	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 67A		Lab ID: 70393989052		Collected: 11/25/25 15:16		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:28	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: 67B		Lab ID: 70393989053		Collected: 11/25/25 15:16		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:29	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 68A		Lab ID: 70393989054		Collected: 11/25/25 15:25		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:30	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 68B		Lab ID: 70393989055		Collected: 11/25/25 15:25		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:31	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 65A		Lab ID: 70393989056		Collected: 11/25/25 15:23		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 65B		Lab ID: 70393989057		Collected: 11/25/25 15:23		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:34	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 70A		Lab ID: 70393989058		Collected: 11/25/25 15:28		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:35	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: 70B		Lab ID: 70393989059		Collected: 11/25/25 15:28		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/08/25 17:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: F12B		Lab ID: 70393989060		Collected: 11/25/25 15:30		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/09/25 11:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: FOOTBALL STORAGE		Lab ID: 70393989061	Collected: 11/25/25 17:20	Received: 11/26/25 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	34.2	ug/L	1.0	1	12/10/25 07:17	12/10/25 17:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: F18A		Lab ID: 70393989062		Collected: 11/25/25 17:22		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.1	ug/L	1.0	1		12/09/25 11:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: F18B		Lab ID: 70393989063		Collected: 11/25/25 17:22		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	13.0	ug/L	1.0	1	12/10/25 07:17	12/10/25 17:51	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

Sample: F16		Lab ID: 70393989064		Collected: 11/25/25 17:35		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/09/25 11:39	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Sample: US		Lab ID: 70393989065		Collected: 11/25/25 17:35		Received: 11/26/25 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/09/25 11:40	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

QC Batch:	431520	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70393989001, 70393989002, 70393989003, 70393989004, 70393989005, 70393989007, 70393989011, 70393989012, 70393989014, 70393989015, 70393989016, 70393989017, 70393989018		

METHOD BLANK:	2310563	Matrix:	Water
Associated Lab Samples:	70393989001, 70393989002, 70393989003, 70393989004, 70393989005, 70393989007, 70393989011, 70393989012, 70393989014, 70393989015, 70393989016, 70393989017, 70393989018		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/08/25 15:42	

LABORATORY CONTROL SAMPLE:	2310564					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.2	100	85-115	

MATRIX SPIKE SAMPLE:	2310566						
Parameter	Units	70393869001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.2	50	54.3	104	70-130	

MATRIX SPIKE SAMPLE:	2310568						
Parameter	Units	70393869002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.3	50	57.6	109	70-130	

SAMPLE DUPLICATE: 2310565					
		70393869001	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	2.2	2.1	2	

SAMPLE DUPLICATE: 2310567					
		70393869002	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	3.3	3.1	4	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

QC Batch:	431544	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70393989020, 70393989021, 70393989022, 70393989023, 70393989024, 70393989025, 70393989026, 70393989027, 70393989028, 70393989029, 70393989030, 70393989031, 70393989032, 70393989033, 70393989034, 70393989035, 70393989036, 70393989037, 70393989038, 70393989039		

METHOD BLANK:	2310678	Matrix:	Water
Associated Lab Samples:	70393989020, 70393989021, 70393989022, 70393989023, 70393989024, 70393989025, 70393989026, 70393989027, 70393989028, 70393989029, 70393989030, 70393989031, 70393989032, 70393989033, 70393989034, 70393989035, 70393989036, 70393989037, 70393989038, 70393989039		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/08/25 16:20	

LABORATORY CONTROL SAMPLE:	2310679					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.0	98	85-115	

MATRIX SPIKE SAMPLE:		2310681					
		70393989020	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	56.4	113	70-130	

MATRIX SPIKE SAMPLE:		2310683					
		70393989021	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.3	50	60.4	116	70-130	

SAMPLE DUPLICATE:	2310680				
Parameter	Units	70393989020 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	2310682				
Parameter	Units	70393989021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.3	2.2	3	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

QC Batch:	431546	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70393989040, 70393989041, 70393989042, 70393989043, 70393989044, 70393989045, 70393989046, 70393989047, 70393989048, 70393989049, 70393989050, 70393989051, 70393989052, 70393989053, 70393989054, 70393989055, 70393989056, 70393989057, 70393989058, 70393989059		

METHOD BLANK:	2310689	Matrix:	Water
Associated Lab Samples:	70393989040, 70393989041, 70393989042, 70393989043, 70393989044, 70393989045, 70393989046, 70393989047, 70393989048, 70393989049, 70393989050, 70393989051, 70393989052, 70393989053, 70393989054, 70393989055, 70393989056, 70393989057, 70393989058, 70393989059		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/08/25 17:00	

LABORATORY CONTROL SAMPLE:	2310690					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.2	100	85-115	

MATRIX SPIKE SAMPLE:	2310692						
Parameter	Units	70393989040 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	58.3	116	70-130	

MATRIX SPIKE SAMPLE:	2310694						
Parameter	Units	70393989041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	61.8	124	70-130	

SAMPLE DUPLICATE:	2310691				
Parameter	Units	70393989040 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	2310693				
Parameter	Units	70393989041 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

QC Batch: 431679 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70393989060, 70393989062, 70393989064, 70393989065

METHOD BLANK: 2311740 Matrix: Water
Associated Lab Samples: 70393989060, 70393989062, 70393989064, 70393989065

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/09/25 11:24	

LABORATORY CONTROL SAMPLE: 2311741

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.4	99	85-115	

MATRIX SPIKE SAMPLE: 2311743

Parameter	Units	70393989060 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	61.8	124	70-130	

MATRIX SPIKE SAMPLE: 2311745

Parameter	Units	70393989062 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	8.1	50	65.1	114	70-130	

SAMPLE DUPLICATE: 2311742

Parameter	Units	70393989060 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 2311744

Parameter	Units	70393989062 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	8.1	7.9	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

QC Batch:	431455	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70393989006, 70393989008, 70393989009, 70393989010, 70393989013

METHOD BLANK: 2310261

Matrix: Water

Associated Lab Samples: 70393989006, 70393989008, 70393989009, 70393989010, 70393989013

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/08/25 17:38	

LABORATORY CONTROL SAMPLE: 2310262

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE: 2310266

Parameter	Units	70393989008 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	47.1	50	109	124	70-130	

MATRIX SPIKE SAMPLE: 2310513

Parameter	Units	70393989009 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.6	50	61.2	107	70-130	

SAMPLE DUPLICATE: 2310265

Parameter	Units	70393989008 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	47.1	47.7	1	

SAMPLE DUPLICATE: 2310512

Parameter	Units	70393989009 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	7.6	7.5	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CAMBRIDGE CSD 11/25
Pace Project No.: 70393989

QC Batch: 431901 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70393989019, 70393989061, 70393989063

METHOD BLANK: 2313884 Matrix: Water
Associated Lab Samples: 70393989019, 70393989061, 70393989063

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/25 17:45	

LABORATORY CONTROL SAMPLE: 2313885

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.3	101	85-115	

MATRIX SPIKE SAMPLE: 2313887

Parameter	Units	70394372006 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	153	50	198	90	70-130	

MATRIX SPIKE SAMPLE: 2314013

Parameter	Units	70394117022 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.6	50	52.3	101	70-130	

SAMPLE DUPLICATE: 2313886

Parameter	Units	70394372006 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	153	149	2	

SAMPLE DUPLICATE: 2314012

Parameter	Units	70394117022 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.6	149	196 D6	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

BATCH QUALIFIERS

Batch: 431515

[1] The post digestion spike for sample 70393989008 (PDS 2310535) exceeded acceptance criteria for Copper and Silver.

[2] The post digestion spike for sample 70393898009 (PDS 2310537) exceeded acceptance criteria for Copper.

Batch: 431939

[1] The post digestion spike for sample 70394372006 (PDS 2314034) exceeded acceptance criteria for Copper.

[2] The post digestion spike for sample 70394117022 (PDS 2314032) exceeded acceptance criteria for Silver.

ANALYTE QUALIFIERS

D6 The precision between the sample and sample duplicate exceeded laboratory control limits.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70393989006	G15C	EPA 200.8	431455	EPA 200.8	431515
70393989008	B1B7	EPA 200.8	431455	EPA 200.8	431515
70393989009	B1B9	EPA 200.8	431455	EPA 200.8	431515
70393989010	B1B6	EPA 200.8	431455	EPA 200.8	431515
70393989013	KITCHEN N	EPA 200.8	431455	EPA 200.8	431515
70393989019	G3	EPA 200.8	431901	EPA 200.8	431939
70393989061	FOOTBALL STORAGE	EPA 200.8	431901	EPA 200.8	431939
70393989063	F18B	EPA 200.8	431901	EPA 200.8	431939
70393989001	G7B	EPA 200.8	431520		
70393989002	G11A	EPA 200.8	431520		
70393989003	G11B	EPA 200.8	431520		
70393989004	G15A	EPA 200.8	431520		
70393989005	G15B	EPA 200.8	431520		
70393989007	F17	EPA 200.8	431520		
70393989011	KITCHEN L	EPA 200.8	431520		
70393989012	KITCHEN M	EPA 200.8	431520		
70393989014	F14	EPA 200.8	431520		
70393989015	C1C	EPA 200.8	431520		
70393989016	C1D	EPA 200.8	431520		
70393989017	C2C	EPA 200.8	431520		
70393989018	C2D	EPA 200.8	431520		
70393989020	G7A	EPA 200.8	431544		
70393989021	KITCHEN B	EPA 200.8	431544		
70393989022	KITCHEN C	EPA 200.8	431544		
70393989023	KITCHEN D	EPA 200.8	431544		
70393989024	KITCHEN E	EPA 200.8	431544		
70393989025	KITCHEN F	EPA 200.8	431544		
70393989026	KITCHEN G	EPA 200.8	431544		
70393989027	KITCHEN H	EPA 200.8	431544		
70393989028	KITCHEN I	EPA 200.8	431544		
70393989029	KITCHEN J	EPA 200.8	431544		
70393989030	KITCHEN K	EPA 200.8	431544		
70393989031	64	EPA 200.8	431544		
70393989032	80	EPA 200.8	431544		
70393989033	82	EPA 200.8	431544		
70393989034	84A	EPA 200.8	431544		
70393989035	84B	EPA 200.8	431544		
70393989036	84C	EPA 200.8	431544		
70393989037	84D	EPA 200.8	431544		
70393989038	84E	EPA 200.8	431544		
70393989039	84F	EPA 200.8	431544		
70393989040	KITCHEN A	EPA 200.8	431546		
70393989041	F12C	EPA 200.8	431546		
70393989042	F13	EPA 200.8	431546		
70393989043	24A	EPA 200.8	431546		
70393989044	24B	EPA 200.8	431546		
70393989045	23A	EPA 200.8	431546		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CAMBRIDGE CSD 11/25

Pace Project No.: 70393989

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70393989046	23B	EPA 200.8	431546		
70393989047	58	EPA 200.8	431546		
70393989048	60	EPA 200.8	431546		
70393989049	F12A	EPA 200.8	431546		
70393989050	62	EPA 200.8	431546		
70393989051	66A	EPA 200.8	431546		
70393989052	67A	EPA 200.8	431546		
70393989053	67B	EPA 200.8	431546		
70393989054	68A	EPA 200.8	431546		
70393989055	68B	EPA 200.8	431546		
70393989056	65A	EPA 200.8	431546		
70393989057	65B	EPA 200.8	431546		
70393989058	70A	EPA 200.8	431546		
70393989059	70B	EPA 200.8	431546		
70393989060	F12B	EPA 200.8	431679		
70393989062	F18A	EPA 200.8	431679		
70393989064	F16	EPA 200.8	431679		
70393989065	US	EPA 200.8	431679		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

W0#: 70393989



70393989

Pace® Location Requested (City/State): CHAIN-OF-CUSTODY Analytical Request Document
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: CAMBRIDGE CSD
Street Address: 245 PARK ST
CAMBRIDGE MA 02142
Phone #: 617-852-7143
E-Mail: PACE.AUSTIN@CAMBRIDGECSD.ORG
City E-Mail:

Customer Project #:
Project Name:
Site Collection Info/Facility ID (as applicable): SAME AS ABOVE
Time Zone Collected: [] AK [] PT [] MT [] CT [] ET
Data Deliverables: [] Level II [] Level III [] Level IV [] EQUIS [] Other:
Rush (Pre-approval required): [] Same Day [] 1 Day [] 2 Day [] 3 Day Other:
Date Results Requested:
Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Biossoid (BS), Other (OT)

Country / State origin of sample(s): Reportable [] Yes [] No
Regulatory Program (DW, RCRA, etc.) as applicable:
DW PWSID # or WW Permit # as applicable:
Field Filtered (if applicable): [] Yes [] No
Analysis:
Preservation non-conformance identified for sample:

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Residual Chlorine Result	Units
G7b					11/25	448			
G11A						454			
G11b						454			
G15A						458			
G15b						458			
G15c						458			
F17						502			
B1B7						510			
B1B9						509			
B1B6						512			

Additional Instructions from Pace®: Collected By: TJAN CCK
Printed Name: Signature

Received by/Company: Signature: 11/25-25/1208
Received by/Company: Signature: 11/25 1220
Received by/Company: Signature: 11/26 800
Received by/Company: Signature: 11/26 800

Page: of

ENV-FRM-CORQ-0019_v02_110123 ©

CHAIN-OF-CUSTODY Analytical Request Document									
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields									
Pace Company Name: CAMBRIDGE CSD Street Address: 24 S. PARK ST CAMBRIDGE MA 02146		Pace® Location Requested (City/State): Contact/Report to: Rich Austin Phone #: 518-677-8527 x1438 E-Mail: RICH.AUSTIN@CAMBRIDGECSD.ORG Cc E-Mail:		Invoice to: Invoice E-mail: Purchase Order # (if applicable): Quote #:		County / State origin of sample(s): Reportable ☐ Yes ☐ No		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Customer Project #: Project Name:		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Analysis: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID	
Site Collection Info/Facility ID (as applicable): SAME AS ABOVE		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No		Matrix *: Customer Sample ID		Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET	
Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET		Regulatory Program (DW, RGA, etc.) as applicable: Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other _____		Date Results Requested: DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): ☐ Yes ☐ No					

Pace® Location Requested (City/State): CHAIN-OF-CUSTODY Analytical Request Document Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields						LAB USE ONLY - Affix Workorder/Login Label Here Scan QR Code for instructions									
Company Name: CAMBRIDGE CSD Street Address: 24 S. PARK ST CAMBRIDGE MA 02146 Contact/Report To: RICH AUSTIN Phone #: 518-677-8527 X1438 E-Mail: RICH.AUSTIN@cambridgesd.org Cc E-Mail:						**Container Size: [] 1L, [X] 500mL, [] 250mL, [] 125mL, [] 100mL, [] 40mL vial, [] Encore, [] TerraCore, [] 50mL, [] Other ** Preservative Types: (1) None, (2) HNO₃, (3) H₂SO₄, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO₄, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other Identify Container Preservative Type** Specify Container Size**									
Customer Project #: _____ Project Name: _____ Site Collection Info/Facility ID (as applicable): SAME AS ABOVE						Analysis Requested Lab Use Only Preservation non-conformance identified for sample.									
Time Zone Collected: [] AK [] PT [] MT [] CT [X] ET Data Deliverables: [] Level II [] Level III [] Level IV [] EQUUS [] Other _____ * Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Waste (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)						County / State origin of sample(s): _____ Reportable [] Yes [X] No DW PWSID # or WW Permit # as applicable: _____ Field Filtered (if applicable): [] Yes [] No Analysis:									
Matrix * Customer Sample ID Comp / Grab Composite Start Date Time Collected or Composite End Date Time # Cont. Residual Chlorine Result Units						Customer Remarks / Special Conditions / Possible Hazards: Collected By: Printed Name Signature Date/Time: 11-25-25 1200 Date/Time: 11/25 1220 Date/Time: 11/26 8:00 Received by/Company: Signature Date/Time Received by/Company: Signature Date/Time Received by/Company: Signature Date/Time Received by/Company: Signature Date/Time									
Additional Instructions from Pace®: Kitchen A						Tracking Number: Delivered by: [] In-Person [] Courier [] FedEx [] UPS [] Other Page: of									

[illegible]

[illegible]

[illegible]

WO#: 70393989

PM: ALC

Due Date: 12/12/25

CLIENT: CAMBRIDGE

Client Name:

Cambridge

Project #

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☒ Yes ☐ No Seals intact: ☐ Yes ☒ No Temperature Blank Present: ☐ Yes ☒ No

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☐ None ☐ Other Type of Ice: Wet Blue ☒ None

Thermometer Used: 11/24 Correction Factor: 0.1 Samples on ice, cooling process has begun

Cooler Temperature (°C): 14.9 Cooler Temperature Corrected (°C): 14.9 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (☒ N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☐ No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? ☐ Yes ☐ No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents:

	COMMENTS:
Chain of Custody Present: ☒ Yes ☐ No	1.
Chain of Custody Filled Out: ☒ Yes ☐ No	2.
Chain of Custody Relinquished: ☒ Yes ☐ No	3.
Sampler Name & Signature on COC: ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time: ☒ Yes ☐ No	5.
Short Hold Time Analysis (<72hr): ☐ Yes ☒ No	6.
Rush Turn Around Time Requested: ☐ Yes ☒ No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) ☒ Yes ☐ No	8.
Correct Containers Used: ☒ Yes ☐ No	9.
-Pace Containers Used: ☒ Yes ☐ No	10.
Containers Intact: ☒ Yes ☐ No	11.
Filtered volume received for Dissolved tests ☐ Yes ☐ No ☒ N/A	Note: if sediment is visible in the dissolved container.
Sample Labels match COC: ☒ Yes ☐ No	12.
-Includes date/time/ID/Analysis Matrix: SL WT OIL OTHER	

Date and Initials of person checking preservation:

All containers needing preservation have been pH paper Lot # 210524 ☒ Yes ☐ No ☐ N/A	13. ☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, ☒ Yes ☐ No ☐ N/A	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: ☐ Yes ☐ No ☒ N/A	14.
KI starch test strips Lot #	Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #	15.
SM 4500 CN samples checked for sulf ☐ Yes ☐ No ☒ N/A	Positive for Sulfide? Y N
Lead Acetate Strips Lot #	16.
Headspace in ALK Bottle (>6mm): ☐ Yes ☐ No ☒ N/A	17.
Headspace in VOA Vials (>6mm): ☐ Yes ☐ No ☒ N/A	
Trip Blank Present: ☐ Yes ☐ No ☒ N/A	
Trip Blank Custody Seals Present ☐ Yes ☐ No ☒ N/A	

Client Notification/ Resolution:

Person Contacted:

Comments/ Resolution:

Field Data Required?

Y / N

Date/Time:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.