

In response to the lead water laboratory findings, the district has developed a remediation plan that outlines corrective actions that will be taken in response to drinking water samples exceeding the NYS actionable levels for lead. The goal is to protect students and staff health by identifying sources of lead, removing or controlling exposure, and compliance with NYSED and NYDOH regulations.

The following water sources will be eliminated from use and Do Not Drink signage will be displayed and education:

F18A F18B Football Storage      B1B6 B1B9

The following outlets will be changed and retested:

F4A Kitchen N      60      G15C BIB7